

* : cskim@huchems.com
TEL:061-680-4653 FAX:061-680-4539

M/R						
RYM200901547	001	2009/10/14	M05	M05221TRD-002	EA	2.0000
MR200910120013		<u>2009/12/31</u>				
****. TRANSMITTER,D/P,M/D:3051CD2F22A1AM5E8Q4, MEASURING RANGE: ± 623MBAR, MEASURING ELEMENT:DIAPHRAGM, ACCURACY: ± 0.1 OR BETTER, FILL FLUID:INERT FILL(HALOCARBON), MAKER;EMERSON						
RYM200901547	002	2009/10/14	M05	M05221TRD-003	EA	1.0000
MR200910120013		<u>2009/12/31</u>				
****. TRANSMITTER,D/P, M/D;3051CD2F25A1AM5B4E8L4Q4, MEASURING RANGE: ± 623MBAR, MEASURING ELEMENT:DIAPHRAGM(TANTALUM), ACCURACY: ± 0.1 OR BETTER,FILL FLUID:SILICONE, MAKER;EMERSON, FOR 221-LIT-706A/B						
RYM200901547	003	2009/10/14	M05	M05221TRL-001	EA	2.0000
MR200910120013		<u>2009/12/31</u>				
****. TRANSMITTER,D/P, M/D:3051L2FA0FD21AAM5E8, TYPE:FLANGE MOUNT, 3" 150#, MEASURING RANGE: ± 0.6BAR, MEASURING ELEMENT:DIAPHRAGM, MAKER;EMERSON, FOUNDATION FIELDBUS						
RYM200901547	004	2009/10/14	M05	M05221TRL-002	EA	1.0000
MR200910120013		<u>2009/12/31</u>				
****. TRANSMITTER,D/P, M/D:3051L2FE0FD21AAM5E8, TYPE:FLANGE MOUNT, 3" 150#, MEASURING RANGE: ± 0.6BAR, MEASURING ELEMENT:DIAPHRAGM, MAKER;EMERSON						
*** LAST ITEM ***						
: 2009 10 20 16:00						

: